

ADDENDUM 01

Scope of Work clarifications:

1. Window 2.1 to be re-glazed with tempered glass.
2. Add an additional, new layer of 5/8” ‘Quiet Rock ES’ along full length/full height of Board Room side of wall adjoining Expanded Office #5.

Drawing corrections:

1. The natural gas stub indicated adjacent to line ‘D’ northerly of line ‘3’ on Sheets A2.2 and A3.2 is actually a domestic water stub.

End of Addendum 01

Acknowledge receipt of Addendum 01 in the appropriate location on Bid Schedule.

Contact the Architect if additional clarification is needed:

Ellis A Schoichet AIA
EASA Architecture
851 Burlway Road Suite 422, Burlingame CA 94010
650.343.3452 x101